

## ADDENDUM A-01

Project:	Removal of the former Town of Drumheller Public Works Shop	Addendum:	<b>A- 01</b>
Location:	117 7 Avenue SE	Date:	<b>October 21, 2020</b>

### To All Bidders:

<p><b>1. General</b></p> <p>1.1 This addendum shall be read in conjunction with the specifications prepared for the Request for Tender - Removal of the former Town of Drumheller Public Works Shop.</p> <p>1.2 Where inconsistent with the above, this addendum shall govern. This addendum forms an integral part of the Contract Documents and shall be included therein.</p> <p>1.3 No consideration shall be allowed for increases (extras) to the CONTRACT PRICE due to failure of the Contractor or Subcontractor not being familiar with this addendum.</p> <p>1.4 The Bidder shall insert in the Tender Form, the number(s) of the addenda received by them during the quotation period and taken into account by them in preparing their quotation.</p>	
	ADDITIONAL INFORMATION
1.	<p><b>SPECIFICATIONS:</b></p> <ol style="list-style-type: none"> <li>1. The contractor will be responsible to supply, set up and remove 230 ft of security fencing for the removal of the buildings.</li> <li>2. The Town will pay for the tipping fees on <b><u>concrete only</u></b>.</li> <li>3. Contractors to include pricing for tipping fees on all other renovation material hauled to the landfill. Current tipping fee for renovation material is \$62.50 per metric tonne.</li> <li>4. Landfill Hours of Operation Monday Friday 8:00 am – 4:30 PM Saturday 9:00 am – 5:00 PM</li> <li>5. Must adhere to The Town of Drumhellers Community Standards Bylaw 06-19 Noise section 9 (e) Weekdays 7:00am – 10:00pm and Weekends 9:00am - 10:00pm</li> <li>6. Specifications for natural gas generator - Attached</li> </ol>

**End of Addendum A – 01**



Serie No. **H950584029** Spec. **77527E**

**IMPORTANT!**

Model & Serial No. Required When Ordering Parts.  
 Modèle & No. Série Requis Pour Commander Des Pièces.



1400 73rd Avenue N.E.  
 Minneapolis, MN 55432 U.S.A.

Made in U.S.A.

99-2433

SERVICE RATING		STANDBY
HZ:	60	RPM: 1800
PF:	0.8/1.0	BAT: 12
1PH KW:	66.7	KVA: 66.7
3PH KW:	100	KVA: 125

  

3PH VOLTS	AMPS	OPTIONS
120/208	347	
127/220	328	
139/240	301	
240/416	173	
254/440	164	
277/480	150	
120/240	381	

  

1PH VOLTS	AMPS	OPTIONS
120/240	278	

WIRING DIAGRAM: 612-6487-01  
 612-6490-02 unc



For Electrical Equipment Only  
 Pour Matériel Electrique Seul