



## REQUEST FOR QUOTATION

**QUOTATION:**

Penitentiary Lift Station Pump - Equipment Supply

**DATE:**

July 7, 2020

**FROM:**

Bill Adams, Utilities Manager

TOWN OF DRUMHELLER REPRESENTATIVE

**DATE QUOTATION REQUIRED:**

YEAR: 2020

MONTH: July

DAY: 21

TIME: 2:00 pm Local Time

**DELIVER OR MAIL QUOTATION IN A SEALED ENVELOPE CLEARLY MARKED:**

TOWN OF DRUMHELLER,  
224 Centre Street  
Drumheller, Alberta T0J 0Y6

**ATTENTION:** Purchasing Department  
"Pen. Lift Station Pump – Equipment Supply"

YOUR FIRM IS INVITED TO SUBMIT A QUOTATION, PURSUANT TO THE GENERAL CONDITIONS FOR THE SCOPE OF WORK AS DESCRIBED. THE QUOTATION MUST INCLUDE MATERIALS AND OVERHEAD. THIS REQUEST SHALL NOT BE CONSIDERED AUTHORIZATION TO PROCEED WITH THE WORK HEREIN DESCRIBED.

# REQUEST FOR QUOTATION

## **SECTION #1 (TO BE COMPLETED BY TOWN OF DRUMHELLER)**

INITIATOR OF REQUEST: Bill Adams

DATE: YEAR: 2020 MONTH: July DAY: 7

### **SCOPE OF WORK**

The successful bidder will supply:

**One (1) VAUGHAN MODEL S4L-O89 SUBMERSIBLE CHOPPER PUMP,**  
consisting of:

- CASING, cast ductile iron with 4" Class125 ANSI rated discharge flange.
- IMPELLER, CUTTER BAR, UPPER CUTTER AND CUTTER NUT, cast steel, heat treated to minimum 60 Rockwell C Hardness. Impeller dynamically balanced.
- MECHANICAL SEAL, cartridge type with SC faces, as manufactured by Vaughan.
- ELASTOMERS, BUNA N
- BEARINGS, oil bath lubricated ball type.
- BEARING HOUSING, cast ductile iron with piloted motor mount.
- AUTOMATIC OIL LEVEL MONITOR, PVC plastic reservoir with 110 volt switch and INTRINSICALLY SAFE relay, and 25 ft. of hose. (NOT INCLUDED)
- SHAFT, heat treated steel.
- DRIVE, 7.5 KW, 1170 RPM, 575 volt, 3 phase, 60 Hz, 1.15 SF, Explosion Proof (Class 1, Group C & D) submersible motor with tandem mechanical seals, moisture sensors, internal thermostats, and 25 ft. of power cable, 15 minute in air duty, manufactured by Baldor.
- PUMP SUBMITTAL FINISH: Sandblasted and prime coat of Tnemec Perma-Shield PL Series 431 Epoxy and a finish coat of Tnemec Perma-Shield PL Series 431 Epoxy (for a total minimum thickness of 30MDFT). (Except Motor)

FOB: Drumheller Wastewater Treatment Plant  
2490 South Railway Avenue  
Drumheller, Alberta

<b>EVALUATION CRITERIA</b>	
Price	80%
Warranty	10%
Delivery Time	10%

**SECTION #2 (TO BE COMPLETED BY CONTRACTOR)**

1. **TOTAL COST OF PROJECT** (Excluding G.S.T.):

\$ \_\_\_\_\_

QUOTATION SUBMISSION PRICE IN EFFECT FOR **45** DAYS FROM DATE OF ACCEPTANCE FROM TOWN OF DRUMHELLER.

**SECTION #3 (TO BE COMPLETED BY TOWN OF DRUMHELLER)**

**QUOTATION INELIGIBILITY**

QUOTATIONS THAT ARE UNSIGNED, INCOMPLETE, IMPROPERLY SIGNED OR SEALED, CONDITIONAL, ILLEGIBLE, OBSCURE, CONTAIN ARITHMETCAL ERRORS, ERASURES, ALTERATIONS OR IRREGULARITIES OF ANY KIND, MAY BE CONSIDERED INVALID.

THE LOWEST, OR ANY EVALUATED QUOTATION, MAY NOT NECESSARILY BE ACCEPTED. THE TOWN OF DRUMHELLER RESERVES THE RIGHT TO REJECT ANY OR ALL QUOTATIONS, OR TO ACCEPT THE QUOTATION EVALUATED TO BE IN THE BEST INTEREST OF THE TOWN OF DRUMHELLER.

**INTENT**

THE UNDERSIGNED CONTRACTOR HEREBY PROVIDES A QUOTATION TO PERFORM THE PROJECT/WORK AS DESCRIBED WITHIN ITS ENTIRETY FOR THE COST AS DESCRIBED IN SECTION #2, ITEM #1.

**CONTRACTOR:** \_\_\_\_\_

PRINT NAME OF AUTHORIZED PERSONNEL: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

**TOWN OF DRUMHELLER:** \_\_\_\_\_

PRINT NAME OF AUTHORIZED PERSONNEL: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_ SIGNATURE: \_\_\_\_\_

DATE: YEAR  MONTH  DAY

UPON COMPLETION OF SIGNATURES ABOVE, THIS DOCUMENT WILL REPRESENT A CONTRACT AGREEMENT BETWEEN THE CONTRACTOR AND TOWN OF DRUMHELLER.