

Addendum No.01

PROJECT: Wastewater Treatment Plant Lab
Upgrades

PAGE: 1 of 1

DATE: 04/19/2021

VITAL PROJECT NO.: C19-2760

OWNER: Town of Drumheller

Architect:

ISSUED BY: Kristopher McMenamon

DESCRIPTION:

1. GENERAL

- 1.1 This addendum is issued prior to tender closing to provide for revisions as noted herein.
- 1.2 All such revisions will become part of the Work and the effects shall be included in the Tender Price.
- 1.3 All work shall be performed in accordance with the Contract Documents.
- 1.4 This addendum consists of 1 page.

2. M-03 – MCC Room Controls Schematic – Sequence of Operation

- 2.1 SF3.1 will operate at minimum flow rate and the existing relief damper will modulate to maintain the MCC room pressurized relative to the adjacent corridor.
- 2.2 Existing return air damper and outdoor air damper will modulate to maintain room temperature.

3. M-05

- 3.1 EF3.1 – Model error correction. Model number to read SQ-70-VG.

END OF ADDENDUM