

## Addendum No.01

PROJECT: Water Treatment Plant Building  
Management System

PAGE: 1 of 1

DATE: 04/19/2021

VITAL PROJECT NO.: C19-2760

OWNER: Town of Drumheller

Architect:

ISSUED BY: Kristopher McMenamon

### DESCRIPTION:

#### 1. GENERAL

- 1.1 This addendum is issued prior to tender closing to provide for revisions as noted herein.
- 1.2 All such revisions will become part of the Work and the effects shall be included in the Tender Price.
- 1.3 All work shall be performed in accordance with the Contract Documents.
- 1.4 This addendum consists of 1 page.

#### 2. Section 23 09 00 – BMCS General Requirements – Additional Points

- 2.1 Along with the 7 MUA's additional points
  - .1 7 - Exhaust Fan Enable
  - .2 7 - Exhaust Fan Status
  - .3 7 – Exhaust Fan Damper
- 2.2 Add points for 2 additional Furnaces as outline in the specification section
- 2.3 Generator Room
  - .1 3 – Low voltage damper actuators
  - .2 1 – Room temperature Sensor
  - .3 1 – Generator Status

**END OF ADDENDUM**