

# EXHAUST FAN SCHEDULE

EXH. No.	TYPE	W/S	EXT. SP. IN. PA.	FAN RPM	MOTOR WATT	REMARKS	MANUF.	MODEL	ELECTR. CODE
EF-1 EF-10	wall	2124	62	680	540	e/w F80-12 Damper	Penn Domes	NLS 24	208/60/7
EF-5	wall	2966	62	1750	370	e/w F80-12 Damper & SHAFT SEAL	Penn Domes	NA 24	115/60/1
EF-6 & 8	wall	1510	62	590	370	e/w F80-12 Damper	Penn Domes	NLS 24	115/60/1
EF-7	wall	1000	62	470	187	e/w F80-12 Damper	Penn Domes	NLS 24	115/60/1
EF-9	wall	246	62	1350	285	e/w F80-12 Damper	Penn Domes	WNO 20	115/60/1
EF-11	walling	180	12.2	1000	180	NINE DUST FAN w/O SCREW	Penn Zephyr	210 TR	115/60/1
EF-12	walling	95	12.2	1000	180		Penn Zephyr	28	115/60/1
EF-13	WALL	1610	62	590	370	W F80-12 DAMPER	PENN DOMES	NLS 24	115/60/1

⊕ — EPOXY COAT ALL FAN PARTS IN AIRSTREAM

## Underwood McLellan Ltd.

Consulting Engineers and Planners

British Columbia Alberta Saskatchewan  
Manitoba Ontario Nova Scotia  
Yukon Territory Northwest Territories



ENGINEER

FOR REVISIONS  
15 ISSUED FOR CHANGE  
 80.2%  
 REVISION DESCRIPTION

DATE	BY	CHKD	APP'D

