

ADDENDUM A-01

Project:	Request for Proposal – Water Treatment Plant Exhaust Fan Replacement
Addendum:	A-01
Date:	August 2, 2022
Location:	2490 South Railway Avenue, Drumheller, Alberta

To All Bidders:

1. General

- 1.1. This addendum shall be read in conjunction with the Specifications prepared for the Request for Proposal – Water Treatment Plant Exhaust Fan Replacement.
- 1.2. Where inconsistent with the above, this addendum shall govern. This addendum forms an integral part of the Contract Documents and shall be included therein.
- 1.3. No consideration shall be allowed for increases (extras) to the CONTRACT PRICE due to failure of the Contractor or Subcontractor not being familiar with this addendum.
- 1.4. The Bidder shall insert in the Tender Form the number(s) of the addenda received by them during the tendering period and taken into account by them in preparing their tender.

1. CLOSING DATE EXTENSION TO **AUGUST 9, 2022**

The closing date for this Request for Proposal has been extended to 2:00 pm local time on **August 9, 2022**.

2. SCOPE OF WORK – EXHAUST FAN COATING

Exhaust fans EF-5 through EF-8 inclusive, plus EF-13 are to have all in airstream fan components epoxy coated.

3. SCOPE OF WORK – EXHAUST FAN SCHEDULE

See attached original Exhaust Fan Schedule for complete information.

EXHAUST FAN SCHEDULE

EXH. No.	TYPE	W/S	EXT. SP. IN. PA.	FAN RPM	MOTOR WATT	REMARKS	MANUF.	MODEL	ELECTR. CODE
EP-1 EP-10	wall	2124	62	680	540	e/w F80-12 Damper	Penn Domes	NLS 24	208/60/7
EP-5	wall	2966	62	1750	370	e/w F80-12 Damper & SHAFT SEAL	Penn Domes	NA 24	115/60/1
EP-6 & 8	wall	1510	62	590	370	e/w F80-12 Damper	Penn Domes	NLS 24	115/60/1
EP-7	wall	1000	62	470	187	e/w F80-12 Damper	Penn Domes	NLS 24	115/60/1
EP-9	wall	246	62	1300	280	e/w F80-12 Damper	Penn Domes	WNO 20	115/60/1
EP-11	walling	180	12.1	1000	180	NINE DUST FAN w/O GEAR	Penn Zephyr	210 TR	115/60/1
EP-12	walling	95	12.1	1000	180		Penn Zephyr	28	115/60/1
EP-13	WALL	1610	62	590	370	W F80-12 DAMPER	PENN DOMES	NLS 24	115/60/1

⊕ — EPOXY COAT ALL FAN PARTS IN AIRSTREAM

Underwood McLellan Ltd.

Consulting Engineers and Planners

British Columbia Alberta Saskatchewan
Manitoba Ontario Nova Scotia
Yukon Territory Northwest Territories



ENGINEER

FOR REVISIONS
15 ISSUED FOR CHANGE
 80.2%
 REVISION DESCRIPTION

DATE	BY	CHKD	APP'D
10/15/88	J.P.	J.P.	J.P.
DATE	SUPV	DES	CHK
			ENG

