

ADDENDUM A-04

Project:	Request for Quotation – Arena Replacement for Two Mycom Compressors and Motors
Addendum:	A-04
Date:	August 19, 2022
Location:	20 Riverside Drive West, Drumheller, Alberta

To All Bidders:

1. General

- 1.1. This addendum shall be read in conjunction with the Specifications prepared for the Request for Quotation – Arena Replacement for Two Mycom Compressors and Motors.
- 1.2. Where inconsistent with the above, this addendum shall govern. This addendum forms an integral part of the Contract Documents and shall be included therein.
- 1.3. No consideration shall be allowed for increases (extras) to the CONTRACT PRICE due to failure of the Contractor or Subcontractor not being familiar with this addendum.
- 1.4. The Bidder shall insert in the Tender Form the number(s) of the addenda received by them during the tendering period and taken into account by them in preparing their tender.

1. SCOPE OF WORK – OIL SEPARATOR REPLACEMENT

1. Both oil separators will need to be replaced when installing the new compressors.
2. Henry COSM-065 coalescing oil separator with flanged service access is the selection for these Mycom 2M compressor.
3. Please ensure that the proper atmospheric relief protection is installed for each vessel.

End of Addendum A-04