

NOTICE TO POTENTIAL PROPONENTS

ADDENDUM 2

To all Bidders:

The following changes, additions, and/or deletions are hereby made a part of RFP Documents as fully and completely as if the same were fully set forth therein:

2022-013 Aquaplex MAU – Engineering Services	
Date – October 18, 2022	
Item	Detail
A1.1	<p>Clarification on Scope</p> <p>To better clarify the scope of this project, please see the following:</p> <p>Question: What is the motivation behind relocating the MAU from inside the enclosed mechanical room to outside on a new concrete slab?</p> <p><i>Answer: The Town believes that having the unit located outside will increase access for maintenance, having the new unit outside. Relocating the MAU outside is not optional.</i></p> <p>Question: Does the existing MAU provide sufficient air flow and maintain the space temperature?</p> <p><i>Answer: The current MUA does not have sufficient air flow or maintain space temperature.</i></p> <p>Question: What is the level of accuracy required for Pre-Design Cost Estimates and Pre-Tender Cost Estimate? Is rough order of magnitude estimate sufficient?</p> <p><i>Answer: Pre-Design cost estimate shall be a Class D and Pre-Tender Cost Estimate shall be a Class A.</i></p>
Attachments:	
NA	

End of Addendum 2