

# NOTICE TO POTENTIAL PROPONENTS

## ADDENDUM 1

To all Bidders:

The following changes, additions, and/or deletions are hereby made a part of RFT Documents as fully and completely as if the same were fully set forth therein:

<b>Project Name: RFT - Spray Park Drainage Line Improvements</b>	
<b>Date: March 16, 2023</b>	
<b>Item</b>	<b>Detail</b>
<b>A1.1</b>	<b>Question from Pre-Bid Meeting: Will the Drumheller landfill accept the contaminated soil coming from the Spray Park excavation.</b>  <i>Answer: Yes, the Drumheller Landfill will accept the contaminated soil coming from the Spray Park excavation, with the requirement of a Class II Landfill analysis. This Class II Landfill analysis must include chloride and total petroleum hydrocarbons. If the Contractor chooses to use the Drumheller Landfill, it is important to set up an account prior to the start of construction start.</i>
<b>Attachments:</b>  NONE	

**End of Addendum 1**