

**NOTICE TO POTENTIAL PROPONENTS**  
**ADDENDUM 4 – East Coulee Phase 1 & 2**  
**RFT#2023-02-16**

To all Bidders:

The following changes, additions, and/or deletions are hereby made a part of RFT Documents as fully and completely as if the same were fully set forth therein:

<b>Project Name: RFT - East Coulee Phase 1 &amp; 2 #2023-02-16</b>	
<b>Date: March 29, 2023</b>	
<b>Item</b>	<b>Detail</b>
<b>A4.1</b>	<p><b>Clarification on Scope</b></p> <p>To better clarify the scope of this project, please see the following pertaining to East Coulee Phase 2 Bid Item 14: Surface Drainage Structure – Station 1+870:</p> <ol style="list-style-type: none"><li>1. Per DWG C-234, pipe diameter for this cross drain is 900 mm. The drawing also references DWG C-502 as the cross drain detail drawing, but DWG C-502 only shows a cross drain with 600 mm diameter pipe.</li></ol> <p>For the Station 1+870 Surface Drainage Structure, please modify the details shown in DWG C-502 to accommodate 900 mm diameter pipe by enlarging manhole pipe openings and increasing flap and sluice gates to 910 mm diameter sizes. Overall concrete manhole structure size will not change. The detail on DWG C-503 shows the 900 mm diameter pipe upgrade for a double cross drain and can be used as a reference for this modification to the single cross drain structure.</p>
<b>Attachments: N/A</b>	

**End of Addendum 4**