

NOTICE TO POTENTIAL PROPONENTS

ADDENDUM 2

To all Bidders:

The following changes, additions, and/or deletions are hereby made a part of RFT Documents as fully and completely as if the same were fully set forth therein:

Project Name: Stirling Ditch & 2nd Ave (Tender No. 2023-031)																										
Date: May 16, 2023																										
Item	Detail																									
A2.1	<p>What are the Specifications for the GEOCOIR?</p> <p><i>The GEOCOIR should conform to the following specifications.</i></p> <table border="1" style="width: 100%; border-collapse: collapse; margin-left: 20px;"> <thead> <tr> <th style="text-align: center;"><i>Property</i></th> <th style="text-align: center;"><i>Unit</i></th> <th style="text-align: center;"><i>Quantity</i></th> </tr> </thead> <tbody> <tr> <td style="text-align: center;"><i>Bio-Degradable</i></td> <td style="text-align: center;">%</td> <td style="text-align: center;">100</td> </tr> <tr> <td style="text-align: center;"><i>Thickness</i></td> <td style="text-align: center;">mm</td> <td style="text-align: center;">11.3</td> </tr> <tr> <td style="text-align: center;"><i>Ground Cover</i></td> <td style="text-align: center;">%</td> <td style="text-align: center;">79</td> </tr> <tr> <td style="text-align: center;"><i>Tensile Strength</i></td> <td style="text-align: center;">kN/m</td> <td style="text-align: center;">22.3</td> </tr> <tr> <td style="text-align: center;"><i>Life Expectancy</i></td> <td style="text-align: center;">years</td> <td style="text-align: center;">4-5</td> </tr> <tr> <td style="text-align: center;"><i>Flow rate</i></td> <td style="text-align: center;">ft/s</td> <td style="text-align: center;">15</td> </tr> <tr> <td style="text-align: center;"><i>Mass per Unit Area</i></td> <td style="text-align: center;">g/m²</td> <td style="text-align: center;">785</td> </tr> </tbody> </table>		<i>Property</i>	<i>Unit</i>	<i>Quantity</i>	<i>Bio-Degradable</i>	%	100	<i>Thickness</i>	mm	11.3	<i>Ground Cover</i>	%	79	<i>Tensile Strength</i>	kN/m	22.3	<i>Life Expectancy</i>	years	4-5	<i>Flow rate</i>	ft/s	15	<i>Mass per Unit Area</i>	g/m ²	785
<i>Property</i>	<i>Unit</i>	<i>Quantity</i>																								
<i>Bio-Degradable</i>	%	100																								
<i>Thickness</i>	mm	11.3																								
<i>Ground Cover</i>	%	79																								
<i>Tensile Strength</i>	kN/m	22.3																								
<i>Life Expectancy</i>	years	4-5																								
<i>Flow rate</i>	ft/s	15																								
<i>Mass per Unit Area</i>	g/m ²	785																								
Attachments:																										
NONE																										

End of Addendum 2